ठाणे महानगरपालिका

महानगरपालिका भवन, डॉ. अल्मेडा रोड, चंदनवाडी, पांचपाखाडी, ठाणे-४००६०२

THE MUNICIPAL CORPORATIONOF THE CITY OF THANE

प्रदूषण नियंत्रण कक्ष

POLLUTION CONTROL CELL

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Ref./T.M.C./P.C.C./VTN - 16311

Sample No.: 1113/2

Date: 11 February 2021

Water Analysis Report

Name Of the Organisation : **Oakwood Ashwood co-op. HSG So. LTD**

Address: Manpada, Thane

E-mail: oasociety12@gmail.com

Mobile No.: 9619401461

Date of receiving Sample: 08 February 2021

Sample Collected by: By Party (Riya Tech)

Type of Water Sample: Treated STP

Parameters	Results	Limits
pH	**7.32**	6.5-8.5
COD	**22.0**	50 ppm
Suspended Solids	**11**	100 ppm
BOD	**4.0**	10 ppm
Oil & Grease	**BDL(<1.0)**	10 ppm
MPN	**0**	230TC/100 ml
E-Coli	**Absent**	0/100 ml
F-Coli	**Absent**	0/100 ml

All results are in ppm except pH.

Remarks: The analyzed parameters are within limit.

This is the analysis report of the Treated STP sample received to our Vartak Nagar Laboratory on *08 February 2021*. This further acknowledges that you have paid the charges *Rs. 24720/-* vide Receipt No. TMC/HQ/PLC/000323/20-21 dated 08 February 2021.

Analysed By

Salgaonkar.

Nirmitee N. Salgaonkar

Jr. Chemist, PCC

Thane Municipal Corporation, Thane

Approved By

Palkar

Vaishali S. Palkar

Jr. Chemist, PCC

Thane Municipal Corporation, Thane