


SCHEMATIC ELEVATION

KEEP GAP ABOVE AC ONLY 100 mm. (BETTER FOR ADJUSTING SLOPES & SPRINKLERS)

SIDE TABLE OF WHAT? CHECK POLICY. 600 MM

450 above counter as per policy.

CONCEALED.

CHECK POLICY OR REFERENCE DWG SHARED.

1550 JUST IN LINE WITH DADO TOP.

ACME OZONE

4th OCT 2022

ELECTRICAL LEGEND

SYMBOL	TYPE
	15A SWITCH
	WATER HEATER – GEYSER
	EXHAUST FAN
	CEILING FAN (900 MM)
	KITCHEN CEILING FAN (~~600~~ MM) 900 OK FITS.
	CEILING LIGHT POINT
	WALL BRACKET LIGHT
	ELECTRICAL BELL – ?
	BELL POINT → NO BELL POINT FOR ASP1. ONLY VDP.
	SOCKET FOR EXHAUST FAN – WE HAVE CONCEALED WALL/CEILING ROSE.
	SOCKET FOR WATER HEATER
	LIGHTING DISTRIBUTION BOARD – NOT READ ~~ALREADY~~ MENTIONED LVDB LPDB.
	ELV BOX – ?.
	VIDEO DOOR PHONE ✓

4th OCT 2022

1. DO NOT MENTION AC TONNAGE.
2. SWITCH OFF THE DOOR, WINDOW N
3. AC IDU SWITCH OFF FROM CIVIL LAYOUT.
4. REMOVE/SHIFT OVERLAPPING TEXT.
5. CAN WE HAVE THE TOILET TRAP DOOR IN FRONT OF W.C ??

NO DOOR BELL AS PER POLICY.

VDP INTERNAL & EXTERNAL

FD16
FD14
FD1
F.F. SH.
PL. SH 08
VOID
TOI-1
8'0" x 5'0"
TOI-2
5'0" x 8'0"
LIVING & DINING
11'0" x 18'6"
PASSAGE
BEDROOM - 2
10'6" x 12'0"
M. BEDROOM - 1
10'6" x 12'0"
KITCHEN
8'0" x 10'0"
DECK
8'0" x 4'0"
UTILITY
3 UNITS
D2
D3
D4
D5
D6
LVDB
LPDB
SD
SD08
W1
W5
CL
CL2
BL
EQ
TV, AC, BED, FAN IN ONE LINE.
REMOVE TEXT.
SHOW ALL POINTS EXCEPT FOR FRIDGE ON THIS WALL.
KITCHEN TO SHOW 900/3 ϕ dia FAN.
WE HAVE A CONCEALED WALL ROSE. (WALL TO BE IN BLOCKWORK)
KEEP CEILING LIGHT POINTS AS SPRINKLER WILL COME ABOVE D4.

2 BHK
TYPICAL COMMENTS.

SPRINKLER
CL CEILING LIGHT.
BL BRACKET LIGHT.

ACME OZONE
4th OCT 2022