MASTER BEDROOM

LIVING & DINING

KITCHEN

WC

BATH

MB-03
MB-02
MB-01
MB-05
BL-5
BL-4
BL-3
BL-2
BL-1
CL-6
CL-5
CL-4
CL-3
CL-2
CL-1
F-4
F-3
F-2
F-1
P-01
BCH
T-01
T-02
L-01
L-02
L-03
L-04
L-05
L-05A
BR-04A
BR-04
K-01
K-02
K-03
K-04
K-05
BT-01
BT-02
ELV D.B.
ELE D.B.
FULL HEIGHT LEDGE WALL
I.D.U C/L
EQ
1825- critical*
400
1325
500
1225
100
350
150
950
700
375

Check Geyser Location (window opening)

T01 Back to Back with BT01 will not fit in wall

BT01 Needs to be shifted. Water Splash issue.

Center with W-B

L03 AC BackBox will be behind the AC IDU

L04 - shift location

L02 - Can it be on the suggested location (near door) It's a 6 module SB with length up to 205mm Wall is 300 mm

Please Discuss

1 BHK

PALAVA LAKEFRONT

1 BHK

SR.NO	SR.NO	POINT CONTROL	MODULES	HT. OF SB (BTM OF SB FROM SL)	REMARKS
L-01	1	BELL POINT	1	1450MM — 1250	
LIVING-DINING					
L-02	1	BL-1	1	1250MM	
	2	F-1 (ONLY REGULATOR)	2		
	3	6-A SOCKET WITH SWITCH	3		
L-03	1	20A-A.C BACK BOX	2	+250MM FROM BEAM BOTTOM(1350 BEAM — Typ LVL ??	
L-04	1	CL-1	1		
	2	F-2 (ONLY REGULATOR)	2		TO BE PLACED IN 2 ROWS OF 6/8 MODULE BOARDS INSTEAD OF ONE LARGE 10/12 MODULE SQUARE BOX
	3	BL-2	1		
	4	AC (SWITCH)	2	600MM	
	5	6-A - 2 SOCKETS WITH 2 SWITCH	6		
	6	TELEPHONE POINT	1		
	7	INTERCOM	1		
L-05	1	T.V	1		STB + TV ON SINGLE SWITCH [REFER KEY ELEVATION] — Elevation
		6-A - 2 SOCKETS WITH 2 SWITCH	7	600MM	
	2	DATA	1		
L-05A	1	6-A TV SOCKET		850MM ✓	
PASSAGE					
P-01		CL-2	1	1250MM	
ELEC. & ELV. DB				1950MM (TOP OF DB)	
BCH		BELL CHIMER	1	1950MM (TOP)	
KITCHEN & UTILITY					
K-01	1	CL-2	1		
	2	CL-3	1		
	3	F-3 (ONLY REGULATOR)	2	1250MM	
	4	BL-3	1		
	5	EXHAUST FAN	1		
	6	6-A SOCKET & SWITCH (GENERAL)	3		
K-02	1	16-A SOCKET WITH SWITCH FOR REFRIDGERATOR	3	1250MM	
K-03	1	16-A SOCKET & SWITCH FOR MICROWAVE	3	1250MM	
K-04	1	6-A SOCKET WITH SWITCH FOR WATER PURIFIER	3	1600MM	
K-05	1	16-A SOCKET WITH SWITCH FOR WASHING MACHINE	3	1250MM	
BATH					
BT-01	1	BL-4	1		
	2	GEYSER (SWITCH WITH INDICATOR)	1	1250MM	
	3	EXHAUST FAN	1		
	4	6-A SOCKET WITH SWITCH	3		
BT-02	1	20-A SOCKET FOR GEYSER	2	2100MM	Use a BL on Bedroom wall.
WC					
BT-01	1	CL-7	1		
	2	EXHAUST FAN	1	1250MM	
	3	6-A SOCKET WITH SWITCH	3		NOT Req'd in W.C.
MASTER BEDROOM					
MB-01	1	CL-5	1	1250MM	
MB-02					
	1	F-4 (ONLY REGULATOR)	2	600MM	
	2	6-A SOCKET WITH SWITCH	2		
MB-03	1	AC (SWITCH)	2		
	2	6-A SOCKET WITH SWITCH	3	600MM	
	3	CL-6	1		
MB-04	1	TV POINT	1		
	2	6-A - 1 SOCKET WITH 1 SWITCH	5	600MM	STB + TV ON SINGLE SWITCH [REFER KEY ELEVATION]
MB-04A	1	6-A TV SOCKET		850MM	
MB-05	1	20A-A.C BACK BOX	2	+250MM FROM BEAM BOTTOM(1350 BEAM	

Nomenclature for BT-01 in plan

1 BHK