(1)

Remove Text of Pvt. Gordon.

Add Deck & Check Storm Shell drg for reference)

Part plan Required.

17/6/19
OLIVIA
TYP. FLR PLAN

To Be Shown.

Coping to be on Ledge wall. Also change in Elec. drg.

X24 X25 X26 X27 X28 X29 X30 X31 X32 X33 X34 X35 X36 X37 X38 X39 X40 X41 X42 X43 X44

Y15 Y14 Y13 Y12 Y11 Y10 Y9 Y8 Y7 Y6 Y5 Y4 Y3 Y2 Y1 Y0

PRIVATE GARDEN

HORIZONTAL BAND AND FIN AT 3RD FLOOR SLAB LEVEL

ELEVATIONAL FIN TO TERMINATE AT SECOND FLOOR SLAB LEVEL

BEDROOM-2 3050

BEDROOM-1 2750

TOILET-01

MASTER BEDROOM

LIVING/DINING

KITCHEN 2360

UTILITY

STR 2

STR 1

PE 01 2400 X 2450

PE 02 1800 X 1800

F.H.C.

FOYER

FLOOR LOBBY

AS PER VENDOR

Horizontal Band to be added at 3rd, 7th, 10th Floor Slab levels

MASTER TOILET

COMMON TOILET

TOILET-02

ELEVATIONAL FIN (REFER ELEVATION FOR FIN TERMINATION)

SLAB PROJECTION AT FIRST FLOOR SLAB LEVEL

FIN AS PER APPROVED VENDOR DETAIL

FIN AS PER DETAIL

50MM EXPANSION JOINT

Please Remove this line

Please Remove this line


Part plan required.

Door Window Schedule is for 2nd floor. Please check It is also swapped for Doors & windows

Bldg Main Plan to be for Typical level. & Part plan to be for 4/3, 7 & 10th levels

17/6/19 (2)
OLIVIA
TYP. FLR PLAN


- 7 -



DETAIL AT D @ 1:50
HORIZONTAL BAND ENLARGED DETAIL
[INTERNAL ROAD SIDE]

@ 4th, 7th & 10th level.

Do not mention 1st level.



DETAIL AT D @ 1:50
HORIZONTAL BAND ENLARGED DETAIL
[INTERNAL ROAD SIDE]

3rd, 7th & 10th

Ideally Match on regd. But atleast differentiate..

To be Detail @ 'F'.
Has to be mirrored as per plan.

Do not mention 1st level.

17/6/19 (3)
OLIVIA
Text to become TYP-FFR
Highlight 3/4/7/10 Condition
Remove 1st level.

FOURTH FLOOR
THIRD FLOOR
SECOND FLOOR
2900
D4
FFL
UTILITY
KITCHEN
LIVING & DINING
BEDROOM 01
WARDROBE
W1
W3

Drip mould

NON STRUCTURAL RC UPSTAND
10X15 MM DRIP MOULD
FIN AS PER APPROVED VENDOR DETAIL
50 MM Ø MS TUBULAR SECTIONS FINISHED IN APPROVED SHADE & SPECS OF PAINT
DRIP MOULD AS PER DETAIL
WEATHER PROTECTION WITH SLOPE AS INDICATED
WEATHER PROTECTION WITH DRIP MOULD AS PER DETAIL
ALUMINUM SLIDING WINDOW AS PER APPROVED VENDOR DETAIL
VITRIFIED TILE FLOORING AS PER APPROVED SELECTION
1ST,4TH,7TH &10TH FLOOR LEVEL ON INTERNAL ROAD SIDE
HORIZONTAL BANDS AT 1ST,4TH,7TH &10TH FLR LVL ON INTERNAL ROAD SIDE
FOUTH LEVEL ON INTERNAL ROAD SIDE
HORIZONTAL BANDS AT 1ST,4TH,7TH &10TH FLR LVL ON INTERNAL ROAD SIDE
WEATHER PROTECTION WITH DRIP MOULD
RC FIN SFEN IN ELEVATION
VITRIFIED TILE FLOORING AS PER APPROVED SELECTION

WALL SECTION 01
WALL SECTION 02
WALL SECTION 03
WALL SECTION 04
WALL SECTION 05

17/6/16.
OLIVIA
TYP. FLR
Levels
4/7/10?

This is wardrobe
Seen in elevation
as per section
line


FOURTH FLOOR

THIRD FLOOR


SECOND FLOOR

2900


2900




WALL SECTION 06




WALL SECTION 07



WALL SECTION 08



WALL SECTION 09



WALL SECTION 12


Why is hatch different??

17/9/16 (5)
OLIVIA
TYP. FLR

FOURTH FLOOR


2900

THIRD FLOOR




WALL SECTION 04A

Section line to be marked in main plan.




WALL SECTION 05A



WALL SECTION 07A

MENTION → ON Retail side below Section title.

L02-6A
↑
Section Missing



WALL SECTION 12