MAHATRANSCO
Maharashtra State Electricity Transmission Co. Ltd.

Office of the add. Ex. Engineer,
EHV Lines Sub-Division,
Maha. State Elect. Trans. Co. Ltd.
At & Post: Padgha, Tal: Bhiwandi,
Dist. Thane, Maharashtra - 421 101
Phone No. 02522-268250

. REF. NO. Addl.EE/EHV/Lines-SDn/PDG/T- 13 / 92 **Dtd.-** 03.07.2017

To,
M/S PREMIER AUTOMOBILES LTD
AANANT DEVELOPERS PVT LTD (POA FOR OWNER)
107/108, 1st floor Sai Infotech, Patel Chowk, Ghatkopar East.
Mumbai 400 077.

Sub: Information regarding Vertical and Horizontal clearances to be maintained between building and EHV line passing through your premiseat village Mangaon and Kole.

Ref : 1)letter from Aanant Developers Pvt.ltd date 12.6.2017.

With ref. to the above subject, It is hereby inform you that on 19.06.2017 Site inspection is carried out at village Mangaon and Kole in presence of your representative Shree Abhijit Tharwal. As per plot shown by representative of Aanant Developers Pvt.ltd, It is found that there are two EHV lines are passing through your plot these are 1) 100 kV multi Ckt PAL – Dombivali line 2) 220kV Anand Nager –Pal line and Jambhul – Pal line on D/C tower.

For construction of building safe distance of 17.5 mtr from centre of the line for 220kv to be kept i.e. 35 mtr corridor has to be maintained and for 100kv line 11.00 mtr distance to be maintained from centre of the line and corridor of 22 mtr has to be maintained. Voltage level is duly marked in detail plan of land in red ink. Please note that this is not NOC for building construction from MSETCL. You have to apply for NOC separately.

Enclosure:- as above
C.S.W.R .To, The Executive Engineer,
EHV O&M Division, Dombivali.

Additional Executive Engineer
EHV Lines Sub-Division
M.S.E.T.C.L., Padgha.