LODHA BUILDING A BETTER LIFE	PALAVA II	PALAVA City of opportunity	Contract Ref:
			Request for Information
			RFI No: RFI-ARC-A2-15

Cluster: **Building:**

To Design Team: MR. GAURI KULKARNI Date: 29/01/2015

MR. VEERA, MR. DEEPESH

Request For Information

Type of RFI ☐ Contractual/Commercial ☐ Technical

Discipline ☑ Arch. ☑ Structural ☐ HVAC ☐ Electrical ☐ Plumbing ☐ Facade ☐ Others(.....)

We request clarification of the following:

Subject: Ref :- A2 Type → Flor plans (Even, odd, First)

Wall b/w C17 & C18, & wall b/w C19 & C20 is shown as Non structural wall in Arch flor plans.

We did not receive Sform, material. Please refer Structural drawing

Signature of Initiator

Comments from PMO: There is no wall shown in that Area, only Beam is shown and Sform arrived for Beam.

Please suggest course of action.

Signature of PMO K. Venkatesan 29/1/15

Design Comments Arch ☐ Structural ☐ HVAC ☐ MEP ☐ Facade ☐

Signed (LODHA Engineer)

Consultant's Comments. ☐ KAPL ☐ SJC ☐ StuctBom ☐ WSP ☐ TCE ☐ Others (.....)

Signed (Consultant's Engineer)

PALAVA City of opportunity		
	Project Director	**Date: -**
	CC: GM (Commercial)	