PE1,PE2

Done by the owner & builder

1. SHAFT

1.1 Any equipment, power supply or hole not relating to the elevator should not be installed in the hoistway, and all building parts in the hoistway should comply with the fireproof

1.2 Hoistway should be vertical enough with tolerance 0~+25mm/0~30m,0~+30mm/30~60m, 0~+50mm/60m.and its min.horizontal size is regarded as the hoistway size marked in

1.3 Close hoistway should own ventilating hole (usually at the top or bottom) with protection net and the hole square is no less than 1% of the whole hoistway horizontal square.

1.4 It's better that the hoistway is made of concrete. If it is made of brick, the concrete enclosure of 300mm height should be made in the hoistway wall where the guide brackets will be fixed. Besides, the concrete girder of 300mm height, with the same width as that of hoistway, should be the edges of the hole (up and down edge) that is pre-placed for landing door.

2. MACHINE ROOM

2.1 According to requirement of the technical parameter sheet, the power should be lined to . the machine room with protection switch and in lock. The fluctuation of the power should be less then ±7%. The N wire and earth wire should be seperated and the ground resistanceis not more than 4ohm.

2.2 The temperature of the machine room should be kept between 5-40 .

3. PIT

3.1 The pit should be waterproof and the plash should be placed at the corner of the pit.

3.2 The counterweight should be installed on a solid base that stands on the strong floor directly or a counterweight safety should be installed if there, under the pit,is a space big enough for access of person.

4. OTHERS

4.1. All reactions marked in the drawing include impact amendment unless it is separately marked force.

4.2. Definition of the door opening way of landing door: the car door runs left means left opening while people face the car door standing inside the car, and vise versa.

CITY LIFTS / KOYO	DESIGN CHECK		CHECK		DRAWIN DESIGN		PROJECT TITLE	DRAWING No.	REV
	DATE:		SCALE	N.S	APPROVED BY		Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved

PE1,PE2

DESIGN SPECIFICATION

TIITLE	ITEM	EL.NO	DESCRIPTIONS
CAR	CEILING	PE1&PE2	HSS with lights and fan
	C.O.P		KYCOP10 with dotmaxtrix display
	CAR DOOR		HSS
	HAND RAIL		THREE SIDES
	WALL		HSS
	TRANSOM.COLUMN KICK PLATE		N/A
	FLOOR FINISH		MARBLE(PROVIDE 20MM RECESS)
LANDING G.FL ONLY	HALL B/T		KYIND20 with dotmatrix display
	DOOR		HSS
	NARROW JAMB WITHOUT TRANSOM		HSS
LANDING OTHER FL'S	HALL B/T		KYIND20 with dotmatrix display
	DOOR		PAINTED
	NARROW JAMB WITHOUT TRANSOM		PAINTED
FLOOR MARK	G,1-12,14,15,16,17,18	PE1&PE2	G,1-12,14,15,16,17,18
PARKING FL	G,1-12,14,15,16,17,18		G,1-12,14,15,16,17,18
CAR SIGNAL			
HALL LANTERN			

SPECIFICATION OF EQUIPMENTS


ELEVATOR NO.	PE1	PE2
TYPE AND HAND OF TRACTION OF MACHINE	GTW8 11.8 KW	GTW8 6.8 KW
DIAMETER OF MAIN SHAVE	Ø400	Ø400
DIAMETER OF DEFLECTOR SHAVE	Ø400	Ø400
MAIN ROPE	Ø10 -5	Ø10 -4
TYPE OF MOTOR	AC GEARLESS	AC GEARLESS
TYPE OF CAR SAFETY	Progressive	Progressive
TYPE OF CAR GOVERNOR	N / A	N / A
TYPE OF PLATFORM FLOORING	N / A	N / A
CAR RAIL	13K (T89/B)	8K (T75/B)
COUNTERWEIGHT RAIL	8K (T75/B)	5K (TK5A)
TYPE OF CAR BUFFER	Hydraulic	Hydraulic
TYPE OF CWT BUFFER	Hydraulic	Hydraulic
CAR WEIGHT KG	1100 + 120	700 + 120
OVERBALANCE	45%	45%
CWT WEIGHT KG	1670	1000
WEIGHT OF TRACTION MACHINE KG	350	350
TECHNICAL DATA		
TYPE	18 STOPS	18 STOPS
CAPACITY	1020 KG (15 PERSONS)	544 KG (8 PERSONS)
SPEED	1.5 m/s	1.5 m/s
CONTROL	V3F GEARLESS	V3F GEARLESS
OPERATION	DUPLEX	DUPLEX
STOP (SIDE)	G,1-12,14,15,16,17,18	G,1-12,14,15,16,17,18
CAR INTERNAL SIZE	1250(W)*1950(D)*2300(H)	1000(W)*1400(D)*2300(H)
ENTRANCE	900(OP)*2100(H)	800(OP)*2100(H)
DOOR OPERATION	2-PANEL CENTER OPENING AUTOMATIC DOOR	2-PANEL CENTER OPENING AUTOMATIC DOOR


CITY LIFTS / KOYO

DESIGN CHECK		CHECK		DRAWIN DESIGN		PROJECT TITLE	DRAWING No.	REV
DATE:		SCALE	N.S	APPROVED BY		Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved


PE1,PE2

HOISTWAY PLAN






Ref. view X, view XX & view Y in sheet no. 7




CITY CITY LIFTS / KOYO	DESIGN CHECK		CHECK		DRAWIN DESIGN		PROJECT TITLE	DRAWING No.	REV	
	DATE:		SCALE	N.S	APPROVED BY		Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved	

PE1,PE2

Pit Plan Drawing






Force of Support(N)


R1	94000	r1	60000
R2	67000	r2	47000

CITY CITY LIFTS / KOYO	DESIGN CHECK		CHECK		DRAWIN DESIGN		PROJECT TITLE	DRAWING No.	REV
	DATE:		SCALE	N.S	APPROVED BY		Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved

PE1,PE2

Top plane layout






(850mmx850mm)
Openable Lockable
Window by client


Force of Support(N)

R3	49000	r3	39000
R4	54000	r4	44000
R5	20000	r5	20000
R6	16000	r6	15000




By City Lift

J-J



Embedded Steel Plate Details




CITY CITY LIFTS / KOYO


DESIGN CHECK		CHECK		DRAWIN DESIGN		PROJECT TITLE	DRAWING No.	REV	
DATE:		SCALE	N.S	APPROVED BY		Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved	

PE1,PE2

Shaft vertical section



Detail I




Floor	Height(mm)
(OH)18	4600
17	2900
16	2900
15	2900
14	2900
12	2900
11	2900
10	2900
9	2900
8	2900
7	2900
6	2900
5	2900
4	2900
3	2900
2	2900
1	2900
G	3350
Pit	1800


CITY LIFTS / KOYO	DESIGN CHECK		CHECK		DRAWIN DESIGN	PROJECT TITLE	DRAWING No.	REV
	DATE:		SCALE	N.S	APPROVED BY	Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved

PE1,PE2

Entrance elevation
G floor




Landing door layout
G floor




Entrance elevation
18th floor


From XX



From X




From Y




Landing door layout
18th floor

From X'



From Y




As per ID dwgs


CITY LIFTS / KOYO	DESIGN CHECK		CHECK		DRAWIN DESIGN		PROJECT TITLE	DRAWING No.	REV	
	DATE:		SCALE	N.S	APPROVED BY		Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved	

PE1,PE2

Entrance elevation
Other floors



Landing door layout
Other floors




As per ID dwgs


CITY LIFTS / KOYO	DESIGN CHECK		CHECK		DRAWIN DESIGN		PROJECT TITLE	DRAWING No.	REV
	DATE:		SCALE	N.S	APPROVED BY		Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved

PE1,PE2


Top plane layout




From A




From C




From E




From B




From D



From F



HOOK



Process - While casting the wall, plates to be placed and embedded.

Ref. details of plate in sheet no. 5

CITY CITY LIFTS / KOYO

DESIGN CHECK		CHECK		DRAWIN DESIGN		PROJECT TITLE	DRAWING No.	REV	
DATE:		SCALE	N.S	APPROVED BY		Lakeshore Greens–Palava II–A2	TWJ15112411	Client's Approved	