JPCL

JUBILANT PHARMA & CHEMICAL LAB

THE QUALITY & COMMITMENT YOU TRUST

Accreditation: NABL for Chemical & Biology (T-2790 & T-2971)
Certification: FDA for Chemical, Instrumentation & Biology (MH/101584 & TL/Ayu/01-16), ISO9001:2008, ISO14001:2004, ISO18001:2007

Report No.: E/16/0148

Report Date: - 08/08/2016

TEST REPORT

Name of Customer	Lodha Group.		
Address of Customer	Palava - II (Khoni). Near Pagdyacha pada. Taloja MIDC Road. Dombivali (E) 401301		
Name of the Sample	Near QO - 116 3810/1000641 SS2. Sec 3 Kirloskar Engine 250 kvA		
Sampling Done by	Mr. Harshad	Date of Sampling	04/08/2016
Name of Sampler	Vin Tech; Model –EFM -2000	Calibration done on	09/02/2016
Date of sample receipt	04/08/2016	Sample ref. No.	E/16/0148
Date of Analysis	04/08/2016	Analysis done by	Mr. Harshad
Sampling Conditions: NM			

Results of Analysis & protocols of Tests Applied

Sr. No.	Parameter	Method	Result	Unit	Limit as per Consent/CPCB
1	Particulate matter(PM)	By Vin Tech Instrument	88	mg/Nm^3	150
2	Sulphur dioxide(SO_2)		35	ppm	50
3	Oxides of Nitrogen (NOX)		15	ppm	NS
4.	Noise Monitoring	By Noise Meter	94	dbs	150

OPINION: In the opinion of the undersigned the sample referred to above **COMPLIES/NOT COMPLIES** as per specification.

JUBILANT Pharma & Chemical Lab

Analyzed By	Checked By	Approved By
for	ADM	
Mr. Harshad Patil (Chemist/~~Microbiologist~~)	Ms. Ashwini D Mule (QC-Incharge)	Mr. T. S. Rawat (Lab-Manager)

JUBILANT PHARMA CHEMICAL LAB

Surya Gayathri CHS. Ltd., Shop No. 10 to 15, Plot No. D-14/15, Sector no. 6, New Panvel (E), Navi Mumbai - 410 206
Contact No.: 022 - 65233936 / 65133332 / 65643936 / 27450046 / 9819659434 / 9167400988
Email: jubilant.pharmalab@gmail.com / madhuri.deshmukh66@gmail.com

Scanned by CamScanner

JPCL

JUBILANT PHARMA & CHEMICAL LAB

THE QUALITY & COMMITMENT YOU TRUST

Accreditation: NABL for Chemical & Biology (T-2790 & T-2971)
Certification: FDA for Chemical, Instrumentation & Biology (MH/101584 & TL/Ayu/01-16), ISO9001:2008, ISO14001:2004, ISO18001:2007

Report No.: E/16/0149

Report Date: - 08/08/2016

TEST REPORT

Name of Customer	Lodha Group.		
Address of Customer	Palava - II (Khoni), Near Pagdyacha pada, Taloja MIDC Road, Dombivali (E) 401301		
Name of the Sample	Model No- TBD3V6II, Sr. No-f/30/2010078 SS2,Sec 3, Greaves Engine 250 kVA		
Sampling Done by	Mr. Harshad	Date of Sampling	04/08/2016
Name of Sampler	Vin Tech; Model –EFM -2000	Calibration done on	09/02/2016
Date of sample receipt	04/08/2016	Sample ref. No.	E/16/0149
Date of Analysis	04/08/2016	Analysis done by	Mr. Harshad
Sampling Conditions: NM			

Results of Analysis & protocols of Tests Applied

Sr. No.	Parameter	Method	Result	Unit	Limit as per Consent/CPCB
1	Particulate matter(PM)	By Vin Tech Instrument	56	mg/Nm^3	150
2	Sulphur dioxide(SO_2)		31	ppm	50
3	Oxides of Nitrogen (NOX)		13	ppm	NS
4.	Noise Monitoring	By Noise Meter	91	dbs	150

OPINION: In the opinion of the undersigned the sample referred to above **COMPLIES/NOT COMPLIES** as per specification.

JUBILANT Pharma & Chemical lab

Analyzed By	Checked By	Approved By
for Talaye	ADM	
Mr. Harshad Patil (Chemist/~~Microbiologist~~)	**Ms. Ashwini D Mule** (QC-Incharge)	**Mr. T. S. Rawat** (Lab-Manager)

JUBILANT PHARMA CHEMICAL LAB

Surya Gayathri CHS. Ltd., Shop No. 10 to 15, Plot No. D-14/15, Sector no. 6, New Panvel (E), Navi Mumbai - 410 206
Contact No.: 022 - 65233936 / 65133332 / 65643936 / 27450046 / 9819659434 / 9167400988
Email: jubilant.pharmalab@gmail.com / madhuri.deshmukh66@gmail.com

Scanned by CamScanner

JPCL

JUBILANT PHARMA & CHEMICAL LAB

THE QUALITY & COMMITMENT YOU TRUST

Accreditation: NABL for Chemical & Biology (T-2790 & T-2971)
Certification: FDA for Chemical, Instrumentation & Biology (MH/101584 & TL/Ayu/01-16), ISO9001:2008, ISO14001:2004, ISO18001:2007

Report No.: E/16/0150

Report Date: - 08/08/2016

TEST REPORT

Name of Customer	Lodha Group.		
Address of Customer	Palava - II (Khoni), Near Pagdyacha pada, Taloja MIDC Road, Dombivali (E) 401301		
Name of the Sample	Main Office Project /GR12ZG0206(Sector 3) Mahindra Engine 200 kVA		
Sampling Done by	Mr. Harshad	Date of Sampling	04/08/2016
Name of Sampler	Vin Tech: Model –EFM -2000	Calibration done on	09/02/2016
Date of sample receipt	04/08/2016	Sample ref. No.	E/16/0150
Date of Analysis	04/08/2016	Analysis done by	Mr. Harshad
Sampling Conditions: NM			

Results of Analysis & protocols of Tests Applied

Sr. No.	Parameter	Method	Result	Unit	Limit as per Consent/CPCB
1	Particulate matter(PM)	By Vin Tech Instrument	65	mg/Nm^3	150
2	Sulphur dioxide(SO_2)		42	ppm	50
3	Oxides of Nitrogen (NOX)		19	ppm	NS
4.	Noise Monitoring	By Noise Meter	96	dbs	150

OPINION: In the opinion of the undersigned the sample referred to above **COMPLIES/NOT COMPLIES** as per specification.

Analyzed By	Checked By	Approved By
for Talod	ABM	
Mr. Harshad Patil	**Ms. Ashwini D Mule**	**Mr. T. S. Rawat**
(Chemist/~~Microbiologist~~)	**(QC-Incharge)**	**(Lab-Manager)**

JUBILANT PHARMA CHEMICAL LAB

Surya Gayathri CHS. Ltd., Shop No. 10 to 15, Plot No. D-14/15, Sector no. 6, New Panvel (E), Navi Mumbai - 410 206
Contact No.: 022 - 65233936 / 65133332 / 65643936 / 27450046 / 9819659434 / 9167400988
Email: jubilant.pharmalab@gmail.com / madhuri.deshmukh66@gmail.com

Scanned by CamScanner

JPCL

JUBILANT PHARMA & CHEMICAL LAB

THE QUALITY & COMMITMENT YOU EXPECT

Accreditation: NABL for Chemical & Biology (T-2790 & T-2971)
Certification: FDA for Chemical, Instrumentation & Biology (MH/I01584 & TL/Ayu/01-16), ISO9001:2008, ISO14001:2004, ISO18001:2007

Report No.: E/16/0151

Report Date: - 08/08/2016

TEST REPORT

Name of Customer	Lodha Group.		
Address of Customer	Palava - II (Khoni), Near Pagdyacha pada, Taloja MIDC Road, Dombivali (E) 401301		
Name of the Sample	Sr. No –EDIOA208044 SS3, Sec 3 250 KVA		
Sampling Done by	Mr. Harshad	Date of Sampling	04/08/2016
Name of Sampler	Vin Tech; Model –EFM -2000	Calibration done on	09/02/2016
Date of sample receipt	04/08/2016	Sample ref. No.	E/16/0151
Date of Analysis	04/08/2016	Analysis done by	Mr. Harshad
Sampling Conditions: NM			

Results of Analysis & protocols of Tests Applied

Sr. No.	Parameter	Method	Result	Unit	Limit as per Consent/CPCB
1	Particulate matter(PM)	By Vin Tech Instrument	48	mg/Nm^3	150
2	Sulphur dioxide(SO_2)		32	ppm	50
3	Oxides of Nitrogen (NOX)		14	ppm	NS
4.	Noise Monitoring	By Noise Meter	90	dbs	150

OPINION: In the opinion of the undersigned the sample referred to above **COMPLIES/NOT COMPLIES** as per specification.

Analyzed By	Checked By	Approved By
for Talgat	ADm	
Mr. Harshad Patil	**Ms. Ashwini D Mule**	**Mr. T. S. Rawat**
(Chemist/~~Microbiologist~~)	**(QC-Incharge)**	**(Lab-Manager)**

JUBILANT PHARMA & CHEMICAL LAB

Surya Gayathri CHS. Ltd., Shop No. 10 to 15, Plot No. D-14/15, Sector no. 6, New Panvel (E), Navi Mumbai - 410 206
Contact No.: 022 - 65233936 / 65133332 / 65643936 / 27450046 / 9819659434 / 9167400988
Email: jubilant.pharmalab@gmail.com / madhuri.deshmukh66@gmail.com

Scanned by CamScanner

JPCL

JUBILANT PHARMA & CHEMICAL LAB

THE QUALITY & COMMITMENT YOU TRUST

Accreditation: NABL for Chemical & Biology (T-2790 & T-2971)
Certification: FDA for Chemical, Instrumentation & Biology (MH/101584 & TL/Ayu/01-16), ISO9001:2008, ISO14001:2004, ISO18001:2007

Report No.: E/16/0152

Report Date: - 08/08/2016

TEST REPORT

Name of Customer	Lodha Group.		
Address of Customer	Palava - II (Khoni), Near Pagdyacha pada, Taloja MIDC Road, Dombivali (E) 401301		
Name of the Sample	Sr. No – 1310H002253 SS3, Sec 3 275 KVA		
Sampling Done by	Mr. Harshad	Date of Sampling	04/08/2016
Name of Sampler	Vin Tech; Model –EFM -2000	Calibration done on	09/02/2016
Date of sample receipt	04/08/2016	Sample ref. No.	E/16/0152
Date of Analysis	04/08/2016	Analysis done by	Mr. Harshad
Sampling Conditions: NM			

Results of Analysis & protocols of Tests Applied

Sr. No.	Parameter	Method	Result	Unit	Limit as per Consent/CPCB
1	Particulate matter(PM)	By Vin Tech Instrument	72	mg/Nm^3	150
2	Sulphur dioxide(SO_2)		29	ppm	50
3	Oxides of Nitrogen (NOX)		20	ppm	NS
4	Noise Monitoring	By Noise Meter	91	dbs	150

OPINION: In the opinion of the undersigned the sample referred to above **COMPLIES/NOT COMPLIES** as per specification.

Analyzed By	Checked By	Approved By
for Talgut	ADM	
Mr. Harshad Patil	**Ms. Ashwini D Mule**	**Mr. T. S. Rawat**
(Chemist/~~Microbiologist~~)	**(QC-Incharge)**	**(Lab-Manager)**

JUBILANT PHARMA CHEMICAL LAB

Surya Gayathri CHS. Ltd., Shop No. 10 to 15, Plot No. D-14/15, Sector no. 6, New Panvel (E), Navi Mumbai - 410 206
Contact No.: 022 - 65233936 / 65133332 / 65643936 / 27450046 / 9819659434 / 9167400988
Email: jubilant.pharmalab@gmail.com / madhuri.deshmukh66@gmail.com

Scanned by CamScanner

JPCL

JUBILANT PHARMA & CHEMICAL LAB

THE QUALITY & COMMITMENT YOU TRUST

Accreditation: NABL for Chemical & Biology (T-2790 & T-2971)
Certification: FDA for Chemical, Instrumentation & Biology (MH/101584 & TL/Ayu/01-16), ISO9001:2008, ISO14001:2004, ISO18001:2007

Report No.: E/16/0153

Report Date: - 08/08/2016

TEST REPORT

Name of Customer	Lodha Group.		
Address of Customer	Palava - II (Khoni), Near Pagdyacha pada, Taloja MIDC Road, Dombivali (E) 401301		
Name of the Sample	Sr. No – 62655982 , Cummins Engine, Labour Camp. 82.5 KVA		
Sampling Done by	Mr. Harshad	Date of Sampling	04/08/2016
Name of Sampler	Vin Tech: Model –EFM -2000	Calibration done on	09/02/2016
Date of sample receipt	04/08/2016	Sample ref. No.	E/16/0153
Date of Analysis	04/08/2016	Analysis done by	Mr. Harshad
Sampling Conditions: NM			

Results of Analysis & protocols of Tests Applied

Sr. No.	Parameter	Method	Result	Unit	Limit as per Consent/CPCB
1	Particulate matter(PM)	By Vin Tech Instrument	68	mg/Nm^3	150
2	Sulphur dioxide(SO_2)		35	ppm	50
3	Oxides of Nitrogen (NOX)		16	ppm	NS
4.	Noise Monitoring	By Noise Meter	96	dbs	150

OPINION: In the opinion of the undersigned the sample referred to above **COMPLIES/NOT COMPLIES** as per specification.

JUBILANT Pharma & Chemical Lab

Analyzed By

for Talpade

Mr. Harshad Patil
(Chemist/~~Microbiologist~~)

Checked By

ADM

Ms. Ashwini D Mule
(QC-Incharge)

Approved By

Mr. T. S. Rawat
(Lab-Manager)

JUBILANT PHARMA CHEMICAL LAB

Surya Gayathri CHS. Ltd., Shop No. 10 to 15, Plot No. D-14/15, Sector no. 6, New Panvel (E), Navi Mumbai - 410 206
Contact No.: 022 - 65233936 / 65133332 / 65643936 / 27450046 / 9819659434 / 9167400988
Email: jubilant.pharmalab@gmail.com / madhuri.deshmukh66@gmail.com

Scanned by CamScanner