CONTINUOUS WELD (TYP). ALL WELDS TO BE 8MM CONTINUOUS FILLET WELDS U.N.O.

STIFFENERS BOTH SIDES OF COLUMN AS PER STR. DWGS.

+5.750 M T.O.S.

+4.000 M T.O.S.

+0.000 M F.G.L.

TUBE EXTENSION AS PER STR. DWGS.

NO STIFF. AS PER STR. DWGS.

NO STIFFENERS AS PER STR. DWG.

NO STIFFENERS AS PER STR. DWG.

CONFIRM LOCATION WITH ARCH/FACADE

BEAM ONLY ON ONE SIDE OF COLUMN C1

NOT AS PER STRUCTURAL DWGS.

COORDINATE DETAIL AS PER STR. DWGS.

MENTION BOLT SIZES

VIEW A–A

VIEW B–B

VIEW C–C

VIEW D–D

VIEW E–E

VIEW F–F

VIEW G–G

VIEW H–H

VIEW X–X

VIEW Y–Y

DETAIL OF I.No.1

DETAIL OF I.No.1A

DETAIL OF I.No.2

DETAIL OF I.No.4

DETAIL OF I.No.5

DETAIL OF I.No.8

DETAIL OF COLUMN C1
(QTY:–1No.)

APPROVED WITH COMMENTS

NOTE:

1) SHOP DRAWINGS ARE CHECKED FOR STRUCTURAL ACCURACY. ALL DIMENSIONS, LOCATIONS, ORIENTATIONS, INCLUDING TOLERANCES AND CLEARANCES IS THE SOLE RESPONSIBILITY OF THE CONTRACTOR.

2) CONTRACTOR SHALL MAKE SURE ALL DIMENSIONS ARE ACCORDING TO ARCHITECTURAL/STRUCTURAL DRAWINGS. ANY DISCREPANCY SHALL BE BROUGHT TO NOTICE BEFORE FABRICATION.

3) APPOROVAL OF THIS DRAWING DOES NOT ABSOLVE THE CONTRACTOR OF ANY RESPONSIBILITY WITH REGARDS TO ACCURACY AND CORRECTNESS ACCORDING TO DESIGN DRAWINGS.

4) PLEASE FOLLOW WELDS AS PER STRUCTURAL DWGS. IT IS NOTICED THAT ALL WELDS ARE FILLET WELDS. THIS IS NOT THE CASE IN THE STRUCTURAL DWGS.

REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED

REVISION

CLIENT:–
LODHA GROUP PVT. LTD.

CONSULTING ARCHITECT:
HAFEEZ CONTRACTOR
ARCHITECT HAFEEZ CONTRACTOR

STRUCTURAL CONSULTANTS:
Dr Kelkar Designs Pvt.Ltd.

CONTRACTOR:–
SHRIDHAR FABRICATION COMPANY
S.No.4/4 Narhe Ambegaon RD.,Bhumkar Nagar, Narhe. Tal. Haveli, Dist. Pune–46
Email:–shrifabcompany@gmail.com

DETAIL ENGINEERING CONSULTANT:–
DESHPANDE & ASSOCIATES
Right Bhusari Colony, Kothrud Pune–38

PROJECT:– LODHA PALAVA SALES GALLERY MANPADA DOMBIVALI EST

TITLE:–
DETAIL OF COLUMN C1

SCALE:	DESIGN:	MADE: PRASHANT	DATE:15.06.2021	DWG.No.	REV:
1:25	CHECK:	SHEET: 1 OF 1	REV:	LG–SG–FAB–04	R0