Refer Arch dwg for fin projection

KAPL To check Elevation 'B' opening & shaft not indicated

Part plan reqd @ 4 & 7 levels.

KAPL To provide chajja.

300 depth Beam & 125 thk slab W/o Beam

Possible to Avoid the Beam?? Golam

Span 1600mm

Part plan @ 4 & 7.

FHC (Regular Beam)

Part plan @ 4 & 7

Elec (upstand Beam)

Part plan @ 4 & 7 Water meter (upStand)

KINDLY CHECK (200X800)

-300 SUNK

Pressurization SHAFT (Regular Beam)

No Beam

Elec (upstand Beam)

Watermeter (upstand Beam)

To Be 175mm thk

No Beam

M/E Also to Check

No BEAM.

KAPL TO CONFIRM: 150 thk slab; 120 thk slab

*300 wide & 400 depth Beam

SECTION @ 20 FROM 12 & 13

4 & 7

ELV (regular Beam)

4 & 7

RCC PARDI ABOVE BEAM

PART PLAN AT 4TH, 7TH FLR. LVL.

PART PLAN AT 4TH,7TH FLR. LVL.

BEAM READING DIRECTIONS

LEGEND :-

- SUNK BY 60 MM
- SUNK BY 60 MM
- SUNK BY 200 MM
- SUNK BY 200 MM
- SUNK BY 250 MM
- SERVICE SLAB (SUNK BY 530 MM)

NOTE:- 1) 100MM EXPANSION GAP ASSUMED.
2) DO NOT FOLLOW THE GENERAL DETAIL DRAWING IF DETAIL IS ALREADY IN THE MAIN DRAWING.
3) DO NOT PROVIDE ANY CUTOUT REINF. SURROUNDING THE CUTOUT IF IT IS LESS THAN 250 MM X 250MM.
4) DO NOT PROVIDE ANY CUTOUT REINF. IF IT IS NOT PROVIDED IN THE PLAN.

TYPICAL FLOOR

NOTE:- 1) ALL BEAM SIZES ARE (200 X 650) U.N.O.

No Beam

DB location.

* 300 wide Beam & 400 depth

SHAFTS REQD AS PER MEP.

SHAFTS NOT REQD BY MEP. (No slab to be provided & to be closed by Blockwork. Doors to be provided @ every 3rd level)

E4 Typ. floor

29/01/2020.

KAPL TO CHECK THE KINK.

Refer mom. 22-01-2020.

BEAM TO BE 1000 mm

KAPL TO Provide Chajja.

BEAM TO BE 820 mm from SCW slab.

FMC shaft KAPL to indicate in Arch. plan.

KINDLY CHECK THIS AREA AS PER GROUND FLOOR

Section Reqd from KAPL

Plan Reqd @ Beam Bottom level.

820 OK

820 Beam OK

KAPL TO CONFIRM

150 thk Slab

120 thk Slab

SPLIT BEAM @ 1st floor level.

BEAM DEPTH TO BE 1100mm & 300 wide (Same as typ. floor Both 1350 - 250 = 1100)

BEAM READING DIRECTIONS

LEGEND :-

- SUNK BY 60 MM
- SUNK BY 60 MM
- SUNK BY 200 MM
- SUNK BY 200 MM
- SUNK BY 250 MM
- SERVICE SLAB (SUNK BY 530 MM)

NOTE:- 1) 100MM EXPANSION GAP ASSUMED.
2) DO NOT FOLLOW THE GENERAL DETAIL DRAWING IF DETAIL IS ALREADY IN THE MAIN DRAWING.
3) DO NOT PROVIDE ANY CUTOUT REINF. SURROUNDING THE CUTOUT IF IT IS LESS THAN 250 MM X 250MM.
4) DO NOT PROVIDE ANY CUTOUT REINF. IF IT IS NOT PROVIDED IN THE PLAN.

E4 FIRST FLOOR 29/01/2020.

STRUCTURAL FRAMING PLAN AT FIRST FLOOR LEVEL (BLDG. - E4)

NOTE:- 1) ALL BEAM SIZES ARE (200 X 650) U.N.O.